

BLM & CRLP WEEKLY CALL

DATE: Tuesday, March 15, 2022

□ CRLP

- Nick DeMai (CRLP)
- Kaylyn Swartz (AP)
- Jon Shelton (Linde)
- Bob Lein (AP)

- Mike Downey (Messer)
- Nick Haines (Messer)
- Brad Beckley

□ BLM

- Flavio Cardenas
- Emmett Larson
- Melissa

- Dawn Jones
- Rodney Cryer
- Sam Burton

1. ANTITRUST COMPLIANCE GUIDELINES
2. GENERAL ADMINISTRATION
3. PLANT ISSUES, PROJECTS & EVENTS
 - **COVID-19 PREVENTION & RISK MINIMIZATION PROGRAMS**
 - COVID-19 stats continue to decline
 - ACTUAL & NEAR MISS INCIDENTS
 - H2S monitors – Near Miss reported and documented
 - PLANT OPERATIONS REVIEW
 - Nick- Plant remains down
 - Dawn- BLM intends to start up the plant, due to staffing this is not possible at the moment, BLM is pursuing 3rd party contract to do so.
 - Dawn- Line pressure- 590
 - Questions and answers about BLM plant staffing
 - Nick- Outstanding issues that need attention to proceed?
 - Brad- Mechanical integrity concerns
 1. Safety valves, thermal release valves on coalescer
 2. Lifting lugs
 3. Soft seat gas valves
 - Dawn- Concern of lack of expertise going forward
 - Discussion about status of valves and their function
 - Discussion about plant start up
 - WAUKESHA TA WORK PLAN
 - Ongoing Waukesha repairs, Linde is working to have 2 Waukesha's operating soon. Will have more this week on this. Plan is to have 2 by April 1st.
4. ON-GOING OPERATIONS
 - EQUIPMENT STATUS
 - Prism was not able to operate during cold weather, should help during warmer weather.
 - Purge continues
 - Atlas awaiting parts to get the machine back to full service
 - Get DGNA system back up
 - Water heaters are installed
 - TRAINING
 - Operator training and staffing as personnel get sick

- OSHA CLIFFSIDE INSPECTION
 - Final abatement submitted on 2/25/2022